



BRITANNIA FIRE



P50F9-ECO 9Ltr PFAS Free Foam

PFAS-free fire extinguishers help minimise your environmental impact and do not contain fluoro chemicals which are known to contaminate the environment and have a long-lasting detrimental effect. This foam is effective on Class A materials fuelled by wood, paper and textiles as well as Class B fires fuelled by paints, solvents, oils and petrochemical products. The extinguisher has also passed the EN3 test for use on live electrical equipment up to 1000V at a distance of 1m. This multi purpose fire extinguisher has an operational temperature range is from +5°C to +60°C.

Benefits

- 20-year manufacturer's operational corrosion guarantee
- 10-year manufacturing faults and workmanship guarantee
- Environmentally friendly PFAS Free Foam
- Recyclable 
- Long-lasting
- Corrosion resistant
- Super strength aramid fibre material
- Accredited to the highest standards
- No annual service required
- Self maintained annual inspection
- Light weight and easy to use



Manufactured in Great Britain

EN3



0029



Technical Specification

| Model | Capacity (Litres) | Fire Rating | Full Weight (Kgs) | Temp Range | Operating Pressure (Bar) @ 20°C | Discharge Duration (Secs) | Discharge Range (M) | Diameter (mm) | Height (mm) |
|-----------|-------------------|-------------|-------------------|--------------|---------------------------------|---------------------------|---------------------|---------------|-------------|
| P50F9-ECO | 9 | 43A/183B | 11.7 | +5° to +60°C | 12 | 40 | 4+ | 210 | 640 |

Specification

Operating Pressure @ 20°C **12bar**

Test Pressure (PT) **22bar**

Maximum Allowable Pressure (PS) **15.38bar**

Minimum Burst Pressure **55bar**

Cylinder Material **HDPE with Aramid fibre**

Operating Head Material **Brass - C3771 - Nickel Plated**

Component Parts

| Item | Description | Part No. |
|------|-----------------------------|------------------|
| A | Head cap assembly | P50-HC-ASS |
| B | Hose Assembly and Nozzle | P50-HO-ASS |
| C | Oetiker Clip | BR0540 & 541 |
| D | Transport Bracket and Strap | P50-TB9 |
| — | Wall Bracket Normal | P509-BRACKET |
| — | Wall Over Bracket | P50 OVER-BRACKET |

Simple In-House Annual Inspection

The extinguisher maintenance programme is a simple process which staff members can easily carry out.

- If an indicator is in the **RED** segment return to manufacturer or appointed distributor.
- Check the tamper seal is in place. If tamper seal is missing, contact manufacturer or distributor.
- Remove any dust with a clean cloth. Turn upside down to inspect base and locate testing magnet.
- Check both gauges with a magnet to confirm operation.
- Moving magnet from side to side needle should move then return to **GREEN** segment. Return magnet to base.
- Check date is within the operational lifespan (colour coded stud in base gives year of manufacture).

At end of service life, return to manufacturer or distributor for manufacturer's overhaul to extend the lifespan.

- Record yearly inspection date into logbook and mark extinguisher body with permanent marker pen.

